



The Odan/Detech Group Inc.
P: (905) 632-3811
F: (905) 632-3363
5230, SOUTH SERVICE ROAD, UNIT 107
BURLINGTON, ONTARIO, L7L 5K2
www.odandetech.com

**PROPOSED SENIOR LIVING RESIDENTIAL DEVELOPMENT
79 HENDERSON STREET
PORT HOPE, ONTARIO**

PROJECT No.: 21241(PH)

FUNCTIONAL SERVICING & STORMWATER MANAGEMENT REPORT

OWNER:

NAUTICAL LANDS GROUP

Prepared By:

THE ODAN/DETECH GROUP INC.

1st Submission – January 2022

Table of Contents

1.0	BACKGROUND	1
2.0	SCOPE OF WORK	2
3.0	SERVICING DESIGN CONSIDERATIONS.....	2
3.1	Sanitary Wastewater Disposal	2
3.2	Water Distribution.....	5
3.3	Stormwater Management	10
5.0	EROSION CONTROL.....	14
6.0	CONCLUSIONS.....	14

LIST OF TABLES

Table 1 – Summary of Land Uses for Sanitary Flow Calculations.....	2
Table 2 – Existing Hydrant Pressure/Flow Conditions	5
Table 3 – Total Water Demand for the Site – FUS -	6
Table 4 – Total Water Demand for the Site – OBC -	9
Table 5 – Allowable Discharge	10
Table 6 – Storage Summary	11
Table 7 Catchment Characteristics for the Post-Developed Site.....	12
Table 8 – Summary of Flows from Site	12
Table 9 – Summary Information	14

APPENDIX A - SITE

Aerial Photo of Existing Site
Site Plan
Site Statistics
Topography of Existing Site

APPENDIX B - SANITARY

Sanitary Flow Calculations

APPENDIX C - WATER

FUS Calculation Sheets
OBC Calculation prepared by Jain Sustainability Consultants Inc.

APPENDIX D - STORM

Pre-Development Storm Drainage Area Plan
Post-Development Storm Drainage Area Plan
Stage/Storage/Discharge Calculation Sheets
Cultec Stormwater Sizing Sheets (if required)
Rainfall Intensity Chart
Visual OTTHYMO Model
Visual OTTHYMO Output
OGS Sizing Report

APPENDIX E

ODAN/DETECH Group Engineering Drawings
Concept Site Servicing
Concept Site Grading

Note: This report is to be read with the Site Servicing and Site Grading Plans prepared by Odan/Detech.

1.0 BACKGROUND

The property under study is a 1.82 ha site located at 79 Henderson Street in Port Hope. The site is bounded by Henderson Street to the east, a grocery store to the south (Davis' Your Independent Grocer), Home Hardware Building Centre and vacant area to the west, and a vacant area to the north. Presently, the site is vacant land with vegetated cover. Refer to the Aerial Photo of the Existing Site in **Appendix A** for additional details.

It is proposed by Nautical Lands Group (NLG) to construct 36 new townhouses (no basements) and a 4-storey apartment building with 40 two bedroom units and 35 one bedroom units. The rest of the site will be comprised of surface parking and landscape. Refer to **Figure 1** below for further information regarding the proposed layout of the site.

In general, the property surface topography is higher in the north-east and slopes gently towards the south-west. For detailed topography of the existing site conditions, refer to **Appendix A** for the latest topographic survey prepared by Sylvester & Brown Land Surveying Ltd., dated July 23, 2021.




Figure 1 is an Excerpt from the Architectural Site Plan, dated August 5, 2021 and prepared by NLG. For detailed information regarding the layout of the proposed development, please refer to the latest drawings prepared by NGL. For general existing site conditions see **Appendix A**.

2.0 SCOPE OF WORK

THE ODAN/DETECH GROUP INC. was retained by the owner, **Nautical Lands Group**, to review the site, collect data, evaluate the site for the proposed land use and present the findings in an Engineering Report.

This report will evaluate the serviceability of the site with respect to sanitary, water and storm services and also evaluate the stormwater management (SWM) strategy that will be implemented to meet the Municipality of Port Hope design criteria.

3.0 SERVICING DESIGN CONSIDERATIONS

3.1 Sanitary Wastewater Disposal

Existing Condition

On the east side of the subject property, an existing 250mm diameter PVC sanitary sewer is located in the middle of Henderson St, which flows southerly towards the service corridor, where it is connected to the a 300mm diameter PVC sanitary sewer. This continues to the south-west side of the subject property where an existing 300mm diameter PVC sanitary sewer is located within a service corridor that flows northerly. At the mid west side of the property the sewer bends and continues to flow in a westerly direction to Fox Road.

A summary of the existing and proposed land uses for the sanitary flows which outlet to Fox Road are shown in Table 1 below.

Table 1 – Summary of Land Uses for Sanitary Flow Calculations

Land Use	Site Area (ha)	Commercial		Residential	
		Floor Area (m ²)	Total Population	No. of Units	Total Population
Existing	1.822	0	0	0	0
Proposed	1.822	0	0	111	230

i) Pre-Development Site

For calculating the population increase for the site, the existing population was assumed to be zero because the site is vacant land.

ii) Post-Development Site

The following Municipality of Port Hope standards for population densities and flow rates will be used to calculate the sanitary flows from the proposed development.

Residential:

- 1.4 persons/unit for 1 bedroom apartment
- 2.1 persons/unit for 2 bedroom apartment

Flow Rates:

- flow rate of 450 L/person/day – residential

The infiltration factor for the City is 0.26 L/s per hectare.

The above values are based on City of Toronto Design Guidelines as discussed with the Municipality of Port Hope Engineering Department.

Sanitary flows from the proposed development are summarized as follows.

Table 2 – Calculated Sanitary Sewage Flows from Proposed Development	
Peak Flow from Site (L/s)	4.95
Infiltration (L/s)	0.47
Total = Peak Flow + Infiltration (L/s)	5.42

Proposed Sanitary Servicing

Proposed Condition

The proposed development consists of a senior living residential apartment and related senior living townhomes. Refer to the Architectural Statistics in Appendix A are provided for on the Architectural Site Plan.

The proposed site will utilize the existing sanitary sewer located on the service corridor. The site will propose a 200mm diameter sewer to capture the flow from the proposed 36 new townhouses and 75 units 4-storey apartment building. The size of the outlet sewer will be confirmed by Mechanical at the time of detailed design, adjustments may be required at that time.

Based on the population and flow rates the proposed site will have a peak flow of 5.42 L/s. The calculations for the site sanitary flows are included in **Appendix B** and are summarized below in **Table 3**.

Table 3 – Summary of Sanitary Flows from the Site

Location of Outlet	Existing Peak Flow (l/s)	Proposed Peak Flow (l/s)
Henderson Street	0	5.42

3.2 Water Distribution

Existing Condition

There is an existing 300mm diameter ductile iron watermain located on the east side of Henderson Street.

There are existing public fire hydrants located on the Henderson Street of the subject site which cover a portion of said site.

Hydrant flow tests for the hydrants described have been performed by SCG process on January 21st of 2022 with the following results.

Table 2 – Existing Hydrant Pressure/Flow Conditions

Hydrant Location	Static Pressure (Psi)	Flow @ 20 Psi (USGPM)
79 Henderson Street	65.9	3338

Proposed Condition

It is proposed to connect the site to the existing 300mm diameter watermain located on Henderson Street for domestic and fire-fighting purposes. New 200mm fire & 100mm domestic will be provided to the site.

The unit rate and peaking factors of water consumption, minimum pipe size and allowable pressure in line were established from the Municipality of Port Hope Guidelines. The fire flow water demand is calculated as per FUS 1999 manual.

The pressures and volumes must be sufficient for peak hour conditions and under fire conditions as established by the Ontario Building Code 2006. The minimal residual pressure under fire conditions is 140 kpa. (or 20.3 psi).

The firefighting calculations are based on a fire resistive rating of a sprinklered building with protected steel.

Please refer to **Appendix C** for further details.

The water demand of the proposed site is calculated as follows:

Residential Water Demand

- | | | | |
|----|-------------------------------|---|-------------|
| a) | Average Day domestic demand - | using 270L/cap/day
(230 persons, from sanitary calculations) | 0.72 L/sec |
| b) | Peak day demand - | 1.8 x daily demand | 1.30 L/sec |
| c) | Peak hour demand - | 3.0 x daily demand | 2.16 L/sec |
| d) | Fire flow (Fire Resistive) | | 301.3 L/sec |

Table 3 – Total Water Demand for the Site – FUS -

	L/sec	USGM
Peak Day Demand	1.30	20.6
Fire Flow Demand	300	4755
Total Water Demand	301.3	4776
Actual Flow at 20 PSI Residual Pressure	210.6	3338

Based on the hydrant flow testing results and as determined using the FUS method for calculating fire flows the existing main is not sufficient to service the subject development. However, since the FUS is typically used for planning purposes the required fire flows will be based on the OBC at the detailed design stage to show that adequate flows are available to service the building.

In general a residential development requires 150 l/sec (2,378 USGPM) for fire protection. The OBC fire flow calculation for a sprinklered building is provided on the next page based on the same building from a similar development. This shows the required fire flow for this building when sprinklered. The following was provided by Jain Sustainability Consultants Inc. for a similar site proposed in Bradford, Ontario. The full report prepared by JSCI can be found in Appendix



Jan. 17, 2022

**Re: 500 Holland Street W., Bradford ON.
Fire Protection Water Supply Requirement for Part 3 of O.B.C.**

The proposed commercial building at 500 Holland Street W., Bradford ON. is a Seniors apartment building. The entire building is of combustible construction, sprinklered.

The site and building is serviced by municipal water supply (Water flow and pressure test attached)

Existing Site (attached)

The Subject Site is located on the (short description of site and surrounding areas)

To the North: Vacant Land
To the East: Existing Grocery Store
To the West: Langford Blvd
To the South: Miller Park Ave

Calculation: $Q=KVStot$

K: building construction classification

V: building volume

Stot: building property line distances

$Stot = 1+ \sum Stot$

Building classifications by group:

Apartment Building: C (K=18)

Building Volume:

24,625 m³

Building multiple exposures:

18.1 m; Stot = 0





27.6 m; Stot =0

3.0 m 1.5m, Stot=0.5

26.5 m, Stot = 0

$Stot = 1+0+0+0.5+0$

Jain Sustainability Consultants Inc.
7405 East Danbro Crescent,
Mississauga, Ontario, L5N 6P8 Canada

(905) 285-9900 
(905) 567-5246 
mail@jainconsultants.com 
www.jainconsultants.com 

thinking globally, delivering locally

Jain

$Q=18 \times 24,626 \text{ m}^3 \times 1.5$

$Q=664,902 \text{ m}^3$

According to Fire protection Water Supply guideline for Part 3 of OBC A3.2.5.7, Table 2:

Minimum water supply flow rate for $Q \geq 270,000$

Required water supply shall be 9000 L/min (150 L/sec)

Conclusion:

Municipal water supply graph shows sufficient flow and pressure used for sprinkler and inside and outside hose stream requirement as referenced by Article 3.2.5.13 of the Building Code and NFPA 13.

Yours very truly,



D. Jain, M.Eng., M.B.A., P.Eng., C.E.M., L.A.P.



Enclosures

1. Site Plan
2. Water flow and pressure test

As can be seen above and based on the OBC the water demand can be adjusted as shown in Table 4;

	L/sec	USGM
Peak Day Demand	1.30	20.6
Fire Flow Demand	150	2,378
Total Water Demand	151.3	2,398
Actual Flow at 20 PSI Residual Pressure	210.6	3,338

As can be seen above the existing water supply will be adequate to provide the necessary domestic and fire flow to the proposed site under the Ontario Building Code applied sprinklered building calculations. Final calculations will be provided to confirm the above by a qualified sprinkler consultant at the detailed design stage.

3.3 Stormwater Management

Existing Condition

On the south side of the subject property, there is an existing 1.0 meter flat bottom ditch, with 3:1 sloping and a minimum depth of 0.8 meters, located on a service corridor that flows westerly until the southwest corner of the property. It then continues to flow northerly for approximately 83.5 meters where it then changes direction and flows to the west towards Fox Road.

On the east side of the subject property, there is an existing ditch which flows southerly down Henderson Street, and outlets into the existing 1.0 meter flat bottom ditch on the south of the property.

The existing site drains via sheet flow to the existing 1.0 meter flat bottom ditch on service corridor.

Pre Development Flows:

The allowable flows were based on criteria obtained from the Town of Port Hope during a preconsultation meeting. The design criteria provided is to control flows from the site to 17.3 l/s/ha in accordance with the *Stormwater Management and Erosion and Silt Control Report* by Aecom, (2011).

Design storm data for the Town of Port Hope:

2 Year storm event

$$I_2 = 682.562 / (T_c + 4.547)^{0.801}$$

where: I = intensity (mm/hr)
 T_c = time of concentration (min)

100 Year storm event

$$I_{100} = 2181.701 / (T_c + 6.194)^{0.864}$$

where: I = intensity (mm/hr)
 T_c = time of concentration (min)

Table 5 – Allowable Discharge	
Total Area (ha)	Q (l/s)
1.822	31.5

Post Development Flows:

For the purpose of post development analysis, the post development storm tributary areas of the subject site have been identified as shown in **Appendix D**.

In order to control the post development flows to allowable flows, on-site storage by underground storage and a dry pond will be required. Visual OTTHYMO will be used to model and determine the detention volume required. A 0.10m (100mm) Orifice plate will be used to detain flows on site before discharging to the existing ditch on the west side of the property. The stage/storage/discharge properties used to model the flow controls for this site are shown in **Appendix D**. A summary of the site storage is provided in Table 6 below.

Table 6 – Storage Summary		
Storm	Required Storage (m ³)	Provided Storage (m ³)
5 Year	222	743
100 Year	719	743


Visual OTTHYMO 2.3.2. will be used to model and determine the peak flows for 2 year and 100 year storm events. For drainage areas with significant imperviousness the calculation of effective rainfall in Visual OTTHYMO is accomplished using the “Standhyd” method. This method is used in urban watersheds to simulate runoff by combining two parallel standard unit hydrographs resulting from the effective rainfall intensity over the pervious and impervious surfaces. For pervious surfaces, losses are calculated using the SCS modified CN method.

For the purposes of post-development analysis, the proposed site has been divided into post-development tributary areas as shown in **Appendix D**. Refer to the Visual OTTHYMO detailed output file in **Appendix D** for further details. See the following **Table 7** for the description and characteristics of the post-development system.

Table 7 Catchment Characteristics for the Post-Developed Site

Area No.	Area (ha)	Hydrograph Method	% impervious	impervious directly connected %	Loss Method for Pervious	CN for Pervious Area	Initial Abstraction for Pervious	Time to peak (T _p)
Area 1- Rooftop Controlled	0.17	StandHyd	99	99	SCS	80	1	-
Area 2- Rooftop uncontrolled	0.323	StandHyd	99	99	SCS	80	1	-
Area 3- Hardscape	0.699	StandHyd	90	90	SCS	80	1	-
Area 3 - Landscape	0.629	NasHyd	-	-	SCS	80	5	0.167

See schematic of Visual Otthymo Model (100 Year Storm) below:



The following **Table 8** shows a summary of the total peak flows from the site. As shown, the total flow is equal to or less than the allowable flow for each storm event.

Table 8 – Summary of Flows from Site

Storm Event	Allowable Flow (L/s)	Proposed Flow (L/s)
2 Year Storm	31.5	20
100 Year Storm	31.5	30

As can be seen the post development flow is less than the allowable flow for both the 2 and 100 year storm events, thus meeting the Town of Port Hope storm water quantity controls for the proposed development.

Water Quality:

For the purposes of zoning and based on the type of development water quality can be achieved through the use of an adequately sized Oil/Grit Separator or Oil/Grit Filtration Separator in combination with LID's and alternative means to achieve water quality.

Water Quality for the proposed development will be determined at the detailed design stage based on the above noted design principals to meet the required water quality storm events.

Based on the current site plan it is expected that a HydroDome HD 6 will meet the required 80% TSS removal.

For further detailed calculations refer to Appendix D.

5.0 EROSION CONTROL

Erosion and sediment controls for the site will be implemented according to The Ministry of Natural Resources Guidelines on Erosion and Sediment Control for Urban Construction Sites. A detailed erosion control plan is included in the set of drawings.

6.0 CONCLUSIONS

From our investigation, the site is serviceable utilizing existing sanitary, storm and watermain infrastructure adjacent to the site. The post development 2 & 100-year storm design have been maintained at the allocated flow rate for the site.

The following **Table 9** summarizes the components of the proposed development.

Table 9 – Summary Information	
Total Sanitary Flow (L/sec)	5.42
Total Water Demand : (L/sec)	301.3
Allowable release rate from site (L/sec) (100 year storm)	31.5
Actual release rate from site (L/sec) (100 year storm)	30
Total Storm Water Storage Required (m3)	719
Total Storm Water Storage Provided (m3)	743
Quantity Control	100mm Dia. Orifice Plate
Water Quality	Oil Grit Separator

Respectfully Submitted;
The Odan/Detech Group Inc.



Feb. 11/22

Paul Hecimovic, P.Eng.


Handwritten signature of German Verbel in black ink.

German Verbel, Civil E.I.T.

APPENDIX A


AERIAL PHOTO AND SURVEY OF EXISTING SITE

A.1 Aerial Photo of Existing Site



Appendix A – Figure 1: Aerial Photo of Existing Site is an excerpt from Google Maps with the approximate property line shown (**red** line). For detailed information regarding the existing property line and topography site conditions, refer to the latest survey and drawings prepared by Sylvester & Brown Land Surveying Ltd., see also **Appendix A – Figure 2**.

A.2 Site Plan



A.3 Site Statistics

SITE INFO:

TOTAL LAND AREA = 18,218 SQM (4.5 AC)
TOTAL LOT COVERAGE = 27%

5 TOWNHOUSE UNIT BLOCK COUNT: = 4
(8.8% LOT COVERAGE)

- BLOCK AREA = 402 SQM
- 2 BEDROOM UNITS = 12
- 1 BEDROOM UNITS = 8
TOTAL = 20

6 TOWNHOUSE UNIT BLOCK COUNT: = 0
(0% LOT COVERAGE)

- BLOCK AREA = 445 SQM
- 2 BEDROOM UNITS = 0
- 1 BEDROOM UNITS = 0
TOTAL = 0

4 TOWNHOUSE UNIT BLOCK COUNT: = 4
(6.8% LOT COVERAGE)

- BLOCK AREA = 312 SQM
- 2 BEDROOM UNITS = 8
- 1 BEDROOM UNITS = 8
TOTAL = 16

TOTAL TOWNHOUSE UNIT COUNT = 36
(TOTAL TOWNHOUSE LOT COVERAGE = 15.6%)


TOWNHOUSE UNIT BREAK-DOWN:

- 1) 20 TWO BEDROOM UNITS (55%)
- 2) 16 ONE BEDROOM UNITS (45%)

MID-RISE BUILDING INFO:

- BLDG AREA = 2,074 SQM
- LOT COVERAGE = 11.4%
- 4 STOREY
- UNIT MIX:
-- 2 BEDRM UNITS = 40 (52%)
-- 1 BEDROOM UNITS = 35 (48%)
TOTAL UNIT COUNT = 75

A.4 Topography of Existing Site



Appendix A – Figure 2: Topography of Existing Site is topography from Drawing 20-2716, dated July 23, 2021 and prepared by Sylvester & Brown Land Surveying Ltd. For detailed information regarding the existing topography site conditions, refer to the latest survey and drawings prepared by Sylvester & Brown Land Surveying Ltd.

APPENDIX B

SANITARY FLOW CALCULATIONS

ODAN/DETECH GROUP

SANITARY FLOW CALCULATIONS

SCENARIO:

Proposed/Existing Development

This program calculates the sanitary discharge from various land use
As per the City of Toronto Guidelines

FILL IN COLOURED CELLS AS REQUIRED

TOTAL SITE AREA (ha) = 1.822

LAND USE	NUMBER OF UNITS	SITE AREA, (ha)	GROSS FLOOR AREA, m2	TOTAL POPULATION	TOTAL DAILY FLOW (LITERS)	AVERAGE DAILY FLOW l/sec	PEAKING FACTOR, M	TOTAL FLOW FROM LAND USE, l/sec
RESIDENTIAL EX 1 Bedroom, using 1.4 persons/unit	0			0	0	0.00		
RESIDENTIAL PROP 1 Bedroom, using 1.4 persons/unit	35			49	22050	0.26		
RESIDENTIAL EX 2 Bedroom, using 2.1 persons/unit	0			0	0	0.00		
RESIDENTIAL PROP 2 Bedroom, using 2.1 persons/unit	40			84	37800	0.44		
RESIDENTIAL EX 3 Bedroom using 3.1 persons/unit	0			0	0	0.00		
RESIDENTIAL PROP 3 Bedroom using 3.1 persons/unit	0			0	0	0.00		
RESIDENTIAL EX Townhouse using 2.7persons/unit	0			0	0	0.00		
RESIDENTIAL PROP TH using 2.7persons/unit	36			97	43740	0.51		
Total Residential	111			230	103590	1.20	4.13	4.95
COMMERCIAL, Using 100 persons/ha	0			0				
COMMERCIAL, Using 1.1 persons/100 m2	0			0				
OFFICES, Using, 3.3 persons/100m2	0			0				
Total ICI	0	0.00			0	0.00		0.00

TOTAL

P= 230

V1= 103590

Q1= 4.95

Q2= 0.00

QInfl 0.47

Qtot 5.42

$$Q = (MqP/86400) + A * I \text{ (L/sec)}$$

Q1= total flow from Residential Land Use (L/sec)
Q2= total flow from Commercial Land Use (L/sec)
QInfl = total flow from Infiltration (L/sec)
Qtot = total flow (Land use + Infiltration)

where : P is population
q = 240 L/cap/day (Ex Residential)
q = 250 L/cap/day (Ex Commercial/Office)
q = 450 L/cap/day (Proposed)

V1= Total Volume from Land Use in liters


A = gross site area
I = 0.26 L/sec/ha (infiltration rate)
Peaking Factor $M = 1 + [14 / (4 + (P/1000, 1/2))]$

APPENDIX C

FUS CALCULATION SHEET OBC CALCULATION by JSCI


WATER SUPPLY FOR PUBLIC FIRE PROTECTION , FIRE UNDERWRITERS SURVEY
GUIDE FOR DETERMINATION OF REQUIRED FIRE FLOWS

$F = 220 \times C \times \sqrt{A}$
Where:
 F = required fire flow in liters per minute
 C = Coefficient related to the type of construction
 A = the total floor area in square meters (excluding basements) in the building considered

LOCATION:	79 Henderson Street, Port Hope		PROJECT:	4 Unit Blook	
OBC OCCUPANCY:	Residential		PROJECT No:	21241 (PH)	
BUILDING FOOT PRINT (m2):	312			Contents	Charge
# OF STOREYS	1			Non-Combustible	-25%
				Limited Combustible	-15%
				Combustible	0%
CONSTRUCTION CLASS:	Wood Frame			Free Burning	15%
				Rapid Buring	25%
AUTOMATED SPRINKLER PROTECTION		Credit	Total	Coefficient related to type of construction	
NFPA 13 sprinkler standard	No	0%	0%	1.5	Wood Frame
Standard Water Supply	No	0%		1	Ordinary
Fully Supervised System	No	0%		0.8	Non combustible
		0%		0.6	Fire Resistive
CONTENTS FACTOR:	Limited Combustible		CHARGE:	-15%	
EXPOSURE 1 (south)	Distance to Exposure Building (m) Length - Height	22.6	10	Separation	Charge
EXPOSURE 2 (east)	Distance to Exposure Building (m) Length - Height	>45	0	0-3 m	25%
EXPOSURE 3 (west)	Distance to Exposure Building (m) Length - Height	3.6	20	3.1 -10 m	20%
EXPOSURE 4 (north)	Distance to Exposure Building (m) Length - Height	>45	0	10.1 - 20 m	15%
				20.1 - 30 m	10%
				30.1 - 45	5%
				> 45 m	0%
				Firewall	10%
			Total:	30	no more than 75%
ARE BUILDINGS CONTIGUOUS:	NO				
FIRE RESISTANT BUILDING	Are vertical openings and exterior vertical communications protected with a minimum one (1) hr rating?		NO		
CALCULATIONS	C =	1.5	Wood Frame		
	A =	312 m2	Total		STOREY AREAS m2
	F =	5829 L/min			312
Round to Nearest 1000 L/min	F =	6000 L/min	must be > 2000 L/min		0
					0
					0
CORRECTION FACTORS:					
OCCUPANCY	-900	L/min			
FIRE FLOW ADJUSTED FOR OCCUPANCY	5100	L/min			
REDUCTION FOR SPRINKLER	0	L/min			
EXPOSURE CHARGE	1530	L/min			
REQUIRED FIRE FLOW	F =	6630 L/min			
Round to Nearest 1000 L/min	F =	7000 L/min	1849 usgm		
	F =	117 L/sec			


WATER SUPPLY FOR PUBLIC FIRE PROTECTION , FIRE UNDERWRITERS SURVEY
GUIDE FOR DETERMINATION OF REQUIRED FIRE FLOWS

$F = 220 \times C \times \sqrt{A}$
Where:
 F = required fire flow in liters per minute
 C = Coefficient related to the type of construction
 A = the total floor area in square meters (excluding basements) in the building considered

LOCATION:	79 Henderson Street, Port Hope		PROJECT:	4 Unit Blook	
OBC OCCUPANCY:	Residential		PROJECT No:	21241 (PH)	
BUILDING FOOT PRINT (m2):	312			Contents	Charge
# OF STOREYS	1			Non-Combustible	-25%
CONSTRUCTION CLASS:	Wood Frame			Limited Combustible	-15%
				Combustible	0%
AUTOMATED SPRINKLER PROTECTION		Credit	Total	Free Burning	15%
NFPA 13 sprinkler standard	No	0%	0%	Rapid Buring	25%
Standard Water Supply	No	0%			
Fully Supervised System	No	0%			
		0%			
COEFFICIENT RELATED TO TYPE OF CONSTRUCTION					
CONTENTS FACTOR:	Limited Combustible		CHARGE:	-15%	
EXPOSURE 1 (south)	Distance to Exposure Building (m) Length - Height	22.6	10	Separation	Charge
EXPOSURE 2 (east)	Distance to Exposure Building (m) Length - Height	3.6	20	0-3 m	25%
EXPOSURE 3 (west)	Distance to Exposure Building (m) Length - Height	20.9	10	3.1 -10 m	20%
EXPOSURE 4 (north)	Distance to Exposure Building (m) Length - Height	>45	0	10.1 - 20 m	15%
				20.1 - 30 m	10%
				30.1 - 45	5%
				> 45 m	0%
				Firewall	10%
			Total:	40	no more than 75%
ARE BUILDINGS CONTIGUOUS:	NO				
FIRE RESISTANT BUILDING	Are vertical openings and exterior vertical communications protected with a minimum one (1) hr rating?		NO		
CALCULATIONS	C =	1.5	Wood Frame		
	A =	312 m2	Total		
	F =	5829 L/min		STOREY AREAS m2	
Round to Nearest 1000 L/min	F =	6000 L/min	must be > 2000 L/min	312	1
				0	
				0	
				0	
CORRECTION FACTORS:					
OCCUPANCY	-900	L/min			
FIRE FLOW ADJUSTED FOR OCCUPANCY	5100	L/min			
REDUCTION FOR SPRINKLER	0	L/min			
EXPOSURE CHARGE	2040	L/min			
REQUIRED FIRE FLOW	F =	7140 L/min			
Round to Nearest 1000 L/min	F =	7000 L/min	1849 usgm		
	F =	117 L/sec			


WATER SUPPLY FOR PUBLIC FIRE PROTECTION , FIRE UNDERWRITERS SURVEY
GUIDE FOR DETERMINATION OF REQUIRED FIRE FLOWS


$F = 220 \times C \times \sqrt{A}$
Where:
 F = required fire flow in liters per minute
 C = Coefficient related to the type of construction
 A = the total floor area in square meters (excluding basements) in the building considered

LOCATION:	79 Henderson Street, Port Hope		PROJECT:	4 Unit Blook	
OBC OCCUPANCY:	Residential		PROJECT No:	21241 (PH)	
BUILDING FOOT PRINT (m2):	312			Contents	Charge
# OF STOREYS	1			Non-Combustible	-25%
				Limited Combustible	-15%
				Combustible	0%
CONSTRUCTION CLASS:	Wood Frame			Free Burning	15%
				Rapid Buring	25%
AUTOMATED SPRINKLER PROTECTION		Credit	Total	Coefficient related to type of construction	
NFPA 13 sprinkler standard	No	0%	0%	1.5	Wood Frame
Standard Water Supply	No	0%		1	Ordinary
Fully Supervised System	No	0%		0.8	Non combustible
		0%		0.6	Fire Resistive
CONTENTS FACTOR:	Limited Combustible		CHARGE:	-15%	
EXPOSURE 1 (south)	Distance to Exposure Building (m) Length - Height	21.8	10	Separation	Charge
EXPOSURE 2 (east)	Distance to Exposure Building (m) Length - Height	>45	0	0-3 m	25%
EXPOSURE 3 (west)	Distance to Exposure Building (m) Length - Height	3.6	20	3.1 -10 m	20%
EXPOSURE 4 (north)	Distance to Exposure Building (m) Length - Height	22.6	10	10.1 - 20 m	15%
				20.1 - 30 m	10%
				30.1 - 45	5%
				> 45 m	0%
				Firewall	10%
			Total:	40	no more than 75%
ARE BUILDINGS CONTIGUOUS:	NO				
FIRE RESISTANT BUILDING	Are vertical openings and exterior vertical communications protected with a minimum one (1) hr rating?		NO		
CALCULATIONS	C =	1.5	Wood Frame		
	A =	312	m2	Total	STOREY AREAS m2
	F =	5829	L/min		312
Round to Nearest 1000 L/min	F =	6000	L/min	must be > 2000 L/min	0
					0
					0
CORRECTION FACTORS:					
OCCUPANCY	-900	L/min			
FIRE FLOW ADJUSTED FOR OCCUPANCY	5100	L/min			
REDUCTION FOR SPRINKLER	0	L/min			
EXPOSURE CHARGE	2040	L/min			
REQUIRED FIRE FLOW	F =	7140	L/min		
Round to Nearest 1000 L/min	F =	7000	L/min	1849	usgm
	F =	117	L/sec		

WATER SUPPLY FOR PUBLIC FIRE PROTECTION , FIRE UNDERWRITERS SURVEY
GUIDE FOR DETERMINATION OF REQUIRED FIRE FLOWS


$F = 220 \times C \times \sqrt{A}$
Where:
 F = required fire flow in liters per minute
 C = Coefficient related to the type of construction
 A = the total floor area in square meters (excluding basements) in the building considered

LOCATION:	79 Henderson Street, Port Hope		PROJECT:	4 Unit Blook	
OBC OCCUPANCY:	Residential		PROJECT No:	21241 (PH)	
BUILDING FOOT PRINT (m2):	312			Contents	Charge
# OF STOREYS	1			Non-Combustible	-25%
				Limited Combustible	-15%
				Combustible	0%
CONSTRUCTION CLASS:	Wood Frame			Free Burning	15%
				Rapid Buring	25%
AUTOMATED SPRINKLER PROTECTION		Credit	Total	Coefficient related to type of construction	
NFPA 13 sprinkler standard	No	0%	0%	1.5	Wood Frame
Standard Water Supply	No	0%		1	Ordinary
Fully Supervised System	No	0%		0.8	Non combustible
		0%		0.6	Fire Resistive
CONTENTS FACTOR:	Limited Combustible		CHARGE:	-15%	
EXPOSURE 1 (south)	Distance to Exposure Building (m) Length - Height	23.0	10	Separation	Charge
EXPOSURE 2 (east)	Distance to Exposure Building (m) Length - Height	3.6	20	0-3 m	25%
EXPOSURE 3 (west)	Distance to Exposure Building (m) Length - Height	16.8	15	3.1 -10 m	20%
EXPOSURE 4 (north)	Distance to Exposure Building (m) Length - Height	22.6	10	10.1 - 20 m	15%
				20.1 - 30 m	10%
				30.1 - 45	5%
				> 45 m	0%
				Firewall	10%
			Total:	55	no more than 75%
ARE BUILDINGS CONTIGUOUS:	NO				
FIRE RESISTANT BUILDING	Are vertical openings and exterior vertical communications protected with a minimum one (1) hr rating?		NO		
CALCULATIONS	C =	1.5	Wood Frame		
	A =	312 m2	Total		STOREY AREAS m2
	F =	5829 L/min			312
Round to Nearest 1000 L/min	F =	6000 L/min	must be > 2000 L/min		0
					0
					0
CORRECTION FACTORS:					
OCCUPANCY	-900	L/min			
FIRE FLOW ADJUSTED FOR OCCUPANCY	5100	L/min			
REDUCTION FOR SPRINKLER	0	L/min			
EXPOSURE CHARGE	2805	L/min			
REQUIRED FIRE FLOW	F =	7905 L/min			
Round to Nearest 1000 L/min	F =	8000 L/min	2113 usgm		
	F =	133 L/sec			

WATER SUPPLY FOR PUBLIC FIRE PROTECTION , FIRE UNDERWRITERS SURVEY GUIDE FOR DETERMINATION OF REQUIRED FIRE FLOWS									
<p>F = 220 x C x v A Where: <i>F = required fire flow in liters per minute</i> <i>C = Coefficient related to the type of construction</i> <i>A = the total floor area in square meters (excluding basements) in the building considered</i></p>									
LOCATION:	79 Henderson Street, Port Hope			PROJECT:	5 Unit Blook				
OBC OCCUPANCY:	Residential			PROJECT No:	21241 (PH)				
BUILDING FOOT PRINT (m2):	402				Contents	Charge			
# OF STOREYS	1				Non-Combustible	-25%			
					Limited Combustible	-15%			
					Combustible	0%			
CONSTRUCTION CLASS:	Wood Frame				Free Burning	15%			
					Rapid Buring	25%			
AUTOMATED SPRINKLER PROTECTION		Credit	Total		Coefficient related to type of construction				
NFPA 13 sprinkler standard	No	0%	0%		1.5	Wood Frame			
Standard Water Supply	No	0%			1	Ordinary			
Fully Supervised System	No	0%			0.8	Non combustible			
		0%			0.6	Fire Resistive			
CONTENTS FACTOR:	Limited Combustible			CHARGE:	-15%				
EXPOSURE 1 (south)	Distance to Exposure Building (m)				Separation	Charge			
	Length - Height		3.6	20	0-3 m	25%			
EXPOSURE 2 (east)	Distance to Exposure Building (m)		16.8	15	3.1 -10 m	20%			
	Length - Height				10.1 - 20 m	15%			
EXPOSURE 3 (west)	Distance to Exposure Building (m)		>45	0	20.1 - 30 m	10%			
	Length - Height				30.1 - 45	5%			
EXPOSURE 4 (north)	Distance to Exposure Building (m)		>45	0	> 45 m	0%			
	Length - Height				Firewall	10%			
			Total:	35	no more than 75%				
ARE BUILDINGS CONTIGUOUS:	NO								
FIRE RESISTANT BUILDING	Are vertical openings and exterior vertical communications protected with a minimum one (1) hr rating?			NO					
CALCULATIONS	C =	1.5	Wood Frame						
	A =	402	m2	Total		STOREY AREAS m2			
	F =	6616	L/min			402		1	
Round to Nearest 1000 L/min	F =	7000	L/min	must be > 2000 L/min		0			
						0			
						0			
CORRECTION FACTORS:									
OCCUPANCY		-1050	L/min						
FIRE FLOW ADJUSTED FOR OCCUPANCY		5950	L/min						
REDUCTION FOR SPRINKLER		0	L/min						
EXPOSURE CHARGE		2082.5	L/min						
REQUIRED FIRE FLOW	F =	8033	L/min						
Round to Nearest 1000 L/min	F =	8000	L/min	2113 usgm					
	F =	133	L/sec						


WATER SUPPLY FOR PUBLIC FIRE PROTECTION , FIRE UNDERWRITERS SURVEY
GUIDE FOR DETERMINATION OF REQUIRED FIRE FLOWS

$F = 220 \times C \times \sqrt{A}$
Where:
 F = required fire flow in liters per minute
 C = Coefficient related to the type of construction
 A = the total floor area in square meters (excluding basements) in the building considered

LOCATION:	79 Henderson Street, Port Hope		PROJECT:	5 Unit Blook	
OBC OCCUPANCY:	Residential		PROJECT No:	21241 (PH)	
BUILDING FOOT PRINT (m2):	402			Contents	Charge
# OF STOREYS	1			Non-Combustible	-25%
CONSTRUCTION CLASS:	Wood Frame			Limited Combustible	-15%
				Combustible	0%
AUTOMATED SPRINKLER PROTECTION		Credit	Total	Free Burning	15%
NFPA 13 sprinkler standard	No	0%	0%	Rapid Buring	25%
Standard Water Supply	No	0%			
Fully Supervised System	No	0%			
		0%			
COEFFICIENT RELATED TO TYPE OF CONSTRUCTION					
COEFFICIENT RELATED TO TYPE OF CONSTRUCTION				1.5	Wood Frame
				1	Ordinary
				0.8	Non combustible
				0.6	Fire Resistive
CONTENTS FACTOR:	Limited Combustible		CHARGE:	-15%	
EXPOSURE 1 (south)	Distance to Exposure Building (m) Length - Height	7.3	20	Separation	Charge
EXPOSURE 2 (east)	Distance to Exposure Building (m) Length - Height	29.6	10	0-3 m	25%
EXPOSURE 3 (west)	Distance to Exposure Building (m) Length - Height	>45	0	3.1 -10 m	20%
EXPOSURE 4 (north)	Distance to Exposure Building (m) Length - Height	3.6	20	10.1 - 20 m	15%
				20.1 - 30 m	10%
				30.1 - 45	5%
				> 45 m	0%
				Firewall	10%
			Total:	50	no more than 75%
ARE BUILDINGS CONTIGUOUS:	NO				
FIRE RESISTANT BUILDING	Are vertical openings and exterior vertical communications protected with a minimum one (1) hr rating?		NO		
CALCULATIONS	C =	1.5	Wood Frame		
	A =	402	m2	Total	STOREY AREAS m2
	F =	6616	L/min		402
Round to Nearest 1000 L/min	F =	7000	L/min	must be > 2000 L/min	0
					0
					0
CORRECTION FACTORS:					
OCCUPANCY	-1050	L/min			
FIRE FLOW ADJUSTED FOR OCCUPANCY	5950	L/min			
REDUCTION FOR SPRINKLER	0	L/min			
EXPOSURE CHARGE	2975	L/min			
REQUIRED FIRE FLOW	F =	8925	L/min		
Round to Nearest 1000 L/min	F =	9000	L/min	2378	usgm
	F =	150	L/sec		


WATER SUPPLY FOR PUBLIC FIRE PROTECTION , FIRE UNDERWRITERS SURVEY
GUIDE FOR DETERMINATION OF REQUIRED FIRE FLOWS

$F = 220 \times C \times \sqrt{A}$
Where:
 F = required fire flow in liters per minute
 C = Coefficient related to the type of construction
 A = the total floor area in square meters (excluding basements) in the building considered

LOCATION:	79 Henderson Street, Port Hope		PROJECT:	5 Unit Blook	
OBC OCCUPANCY:	Residential		PROJECT No:	21241 (PH)	
BUILDING FOOT PRINT (m2):	402			Contents	Charge
# OF STOREYS	1			Non-Combustible	-25%
				Limited Combustible	-15%
				Combustible	0%
CONSTRUCTION CLASS:	Wood Frame			Free Burning	15%
				Rapid Buring	25%
AUTOMATED SPRINKLER PROTECTION		Credit	Total	Coefficient related to type of construction	
NFPA 13 sprinkler standard	No	0%	0%	1.5	Wood Frame
Standard Water Supply	No	0%		1	Ordinary
Fully Supervised System	No	0%		0.8	Non combustible
		0%		0.6	Fire Resistive
CONTENTS FACTOR:	Limited Combustible		CHARGE:	-15%	
EXPOSURE 1 (south)	Distance to Exposure Building (m) Length - Height	3.6	20	Separation	Charge
EXPOSURE 2 (east)	Distance to Exposure Building (m) Length - Height	14.2	15	0-3 m	25%
EXPOSURE 3 (west)	Distance to Exposure Building (m) Length - Height	> 45	0	3.1 -10 m	20%
EXPOSURE 4 (north)	Distance to Exposure Building (m) Length - Height	7.3	20	10.1 - 20 m	15%
				20.1 - 30 m	10%
				30.1 - 45	5%
				> 45 m	0%
				Firewall	10%
			Total:	55	no more than 75%
ARE BUILDINGS CONTIGUOUS:	NO				
FIRE RESISTANT BUILDING	Are vertical openings and exterior vertical communications protected with a minimum one (1) hr rating?		NO		
CALCULATIONS	C =	1.5	Wood Frame		
	A =	402 m2	Total		STOREY AREAS m2
	F =	6616 L/min			402
Round to Nearest 1000 L/min	F =	7000 L/min	must be > 2000 L/min		0
					0
					0
CORRECTION FACTORS:					
OCCUPANCY	-1050	L/min			
FIRE FLOW ADJUSTED FOR OCCUPANCY	5950	L/min			
REDUCTION FOR SPRINKLER	0	L/min			
EXPOSURE CHARGE	3272.5	L/min			
REQUIRED FIRE FLOW	F =	9223 L/min			
Round to Nearest 1000 L/min	F =	9000 L/min	2378 usgm		
	F =	150 L/sec			

WATER SUPPLY FOR PUBLIC FIRE PROTECTION , FIRE UNDERWRITERS SURVEY
GUIDE FOR DETERMINATION OF REQUIRED FIRE FLOWS

$F = 220 \times C \times \sqrt{A}$
Where:
 F = required fire flow in liters per minute
 C = Coefficient related to the type of construction
 A = the total floor area in square meters (excluding basements) in the building considered

LOCATION:	79 Henderson Street, Port Hope		PROJECT:	5 Unit Blook	
OBC OCCUPANCY:	Residential		PROJECT No:	21241 (PH)	
BUILDING FOOT PRINT (m2):	402			Contents	Charge
# OF STOREYS	1			Non-Combustible	-25%
CONSTRUCTION CLASS:	Wood Frame			Limited Combustible	-15%
				Combustible	0%
AUTOMATED SPRINKLER PROTECTION		Credit	Total	Free Burning	15%
NFPA 13 sprinkler standard	No	0%	0%	Rapid Buring	25%
Standard Water Supply	No	0%			
Fully Supervised System	No	0%			
		0%			
COEFFICIENT RELATED TO TYPE OF CONSTRUCTION					
CONTENTS FACTOR:	Limited Combustible		CHARGE:	-15%	
EXPOSURE 1 (south)	Distance to Exposure Building (m) Length - Height	> 45	0	Separation	Charge
EXPOSURE 2 (east)	Distance to Exposure Building (m) Length - Height	27.7	10	0-3 m	25%
EXPOSURE 3 (west)	Distance to Exposure Building (m) Length - Height	26.8	10	3.1 - 10 m	20%
EXPOSURE 4 (north)	Distance to Exposure Building (m) Length - Height	3.6	20	10.1 - 20 m	15%
				20.1 - 30 m	10%
				30.1 - 45 m	5%
				> 45 m	0%
				Firewall	10%
			Total:	40	no more than 75%
ARE BUILDINGS CONTIGUOUS:	NO				
FIRE RESISTANT BUILDING	Are vertical openings and exterior vertical communications protected with a minimum one (1) hr rating?		NO		
CALCULATIONS	C =	1.5	Wood Frame		
	A =	402 m2	Total		
	F =	6616 L/min		STOREY AREAS m2	
Round to Nearest 1000 L/min	F =	7000 L/min	must be > 2000 L/min	402	1
				0	
				0	
				0	
CORRECTION FACTORS:					
OCCUPANCY	-1050	L/min			
FIRE FLOW ADJUSTED FOR OCCUPANCY	5950	L/min			
REDUCTION FOR SPRINKLER	0	L/min			
EXPOSURE CHARGE	2380	L/min			
REQUIRED FIRE FLOW	F =	8330 L/min			
Round to Nearest 1000 L/min	F =	8000 L/min	2113 usgm		
	F =	133 L/sec			



Jan. 17, 2022

Re: 500 Holland Street W., Bradford ON.
Fire Protection Water Supply Requirement for Part 3 of O.B.C.

The proposed commercial building at 500 Holland Street W., Bradford ON. is a Seniors apartment building. The entire building is of combustible construction, sprinklered.

The site and building is serviced by municipal water supply (Water flow and pressure test attached)

Existing Site (attached)

The Subject Site is located on the (short description of site and surrounding areas)

To the North: Vacant Land
To the East: Existing Grocery Store
To the West: Langford Blvd
To the South: Miller Park Ave

Calculation: $Q=KVStot$

K: building construction classification

V: building volume

Stot: building property line distances

$Stot = 1 + \sum Stot$

Building classifications by group:

Apartment Building: C (K=18)

Building Volume:

24,625 m³

Building multiple exposures:

18.1 m; Stot = 0





27.6 m; Stot = 0

3.0 m 1.5m, Stot=0.5

26.5 m, Stot = 0

$Stot = 1+0+0+0.5+0$

Jain Sustainability Consultants Inc.
7405 East Danbro Crescent,
Mississauga, Ontario, L5N 6P8 Canada

(905) 285-9900 
(905) 567-5246 
mail@jainconsultants.com 
www.jainconsultants.com 

thinking globally, delivering locally

Jain

$Q=18 \times 24,626 \text{ m}^3 \times 1.5$

$Q=664,902 \text{ m}^3$

According to Fire protection Water Supply guideline for Part 3 of OBC A3.2.5.7, Table 2:

Minimum water supply flow rate for $Q \geq 270,000$

Required water supply shall be 9000 L/min (150 L/sec)

Conclusion:

Municipal water supply graph shows sufficient flow and pressure used for sprinkler and inside and outside hose stream requirement as referenced by Article 3.2.5.13 of the Building Code and NFPA 13.

Yours very truly,



D. Jain, M.Eng., M.B.A., P.Eng., C.E.M., L.A.P.



Enclosures

1. Site Plan
2. Water flow and pressure test



FLOWMETRIX
INDU-TECH
PROCESS

Fire Flow Testing Report

Residual Hydrant #
NFPA Colour Code

HY
BLUE

DATE January 25, 2022
TIME 10:00 AM
ADDRESS 79 Henderson Street
Port Hope, ON
L1A 2G3

RESIDUAL HYDRANT INFO.


HYDRANT # HY
N.F.P.A. COLOUR CODE BLUE
STATIC PRESSURE 65.9 psi
RESIDUAL PRESSURE 54.2 psi
PRESSURE DROP 11.1 psi
% PRESSURE DROP 16.8 % psi
Flow on Water Main At Test Hydrant - 20 psi 3338 USGPM

CONTACT INFO
Angela Mariani
Nautical Lands Group
T: (905) 683-1261
E: angela@nlgc.com

FLOW HYDRANT(S) INFO.


HYDRANT ASSET ID	HYD. # PORTS	OUTLET DIAMETER (INCHES)	NOZZLE COEFFICIENT	DIFFUSER TYPE	DIFFUSER COEFFICIENT	PITOT READING (psi)	PITOT FLOW (USGPM)	FLOW METER (USGPM)
HY	2	2.5	Round	LPD250	0.90	26.3	775	0
		2.5	Round	LPD250	0.90	26.3	775	0
Total Flow (USGPM)							1549	0
Total Flow (USGPM)							1549	0

FIRE FLOW CHART



COMMENTS

OPERATOR Ryan Ritchie
OPERATOR
OPERATOR
FIMX Port Hope Municipality
FIMX



APPENDIX D

PRE-DEVELOPMENT STORM DRAINAGE AREA PLAN
POST-DEVELOPMENT STORM DRAINAGE AREA PLAN
STAGE/STORAGE/DISCHARGE CALCULATION SHEETS
CULTEC DESIGN SHEET
VISUAL OTTHYMO MODEL
VISUAL OTTHYMO DESIGN STORM OUTPUT

ORIFICE DISCHARGE CALCULATOR

This program calculates the discharge from a circular orifice when given elevations and orifice diameters by the user.

Discharge based on orifice equ.: $Q = CA \times \text{sqrt}(2gh)$

Orifice Diameter = **0.100** m ← Enter the orifice diameter in metres

Area **0.00785** m²

Discharge Coeff. = **0.620** ← Enter discharge coeff. to use
Orifice Plate

Elev.	Head	Discharge
140.56	0	0.0000
141.20	0.64	0.0173
141.40	0.84	0.0198
141.60	1.04	0.0220
141.80	1.24	0.0240
142.00	1.44	0.0259
142.2	1.64	0.0276
142.4	1.84	0.0293



CULTEC Stormwater Design Calculator


Date:	January 17, 2022
Project Information:	
21241 - PORT HOPE	

INPUT INFO

Calculations Performed By:	
Odan Detech	

RECHARGER 360HD

Recharger 360HD Chamber Specifications		
Height	914	mm
Width	1524	mm
Length	1.27	meters
Installed Length	1.12	meters
Bare Chamber Volume	1.04	cu. meters
Installed Chamber Volume	1.81	cu. meters




Breakdown of Storage Provided by Recharger 360HD Stormwater System		
Within Chambers	72.35	cu. meters
Within Feed Connectors	0.78	cu. meters
Within Stone	70.85	cu. meters
Total Storage Provided	144.0	cu. meters
Total Storage Required	120.00	cu. meters

Materials List

Recharger 360HD		
Total Number of Chambers Required	64	pieces
Chamber Units	64	pieces
End Caps	32	pieces
HVLV FC-48 Feed Connectors	30	pieces
CULTEC No. 410 Non-Woven Geotextile	560	sq. meters
CULTEC No. 4800 Woven Geotextile	59	meters
Stone	177	cu. meters


Based on 2 Internal Manifolds

Bed Detail



Bed Layout Information		
Number of Rows Wide	16	pieces
Number of Chambers Long	4	pieces
Chamber Row Width	28.96	meters
Chamber Row Length	5.24	meters
Bed Width	29.57	meters
Bed Length	5.85	meters
Bed Area Required	172.84	sq. meters
Length of Separator Row	N/A	meters

Bed detail for reference only. Not project specific. Not to scale.



Conceptual graphic only. Not job specific.

[CLICK FOR STAGE-STORAGE REPORT](#)

Cross Section Table Reference			
A	Depth of Stone Base	229	mm
B	Chamber Height	914	mm
C	Depth of Stone Above Units	305	mm
D	Depth of 95% Compacted Fill	305	mm
E	Max. Depth Allowed Above the Chamber	3.66	meters
F	Chamber Width	1524	mm
G	Center to Center Spacing	1.83	meters
H	Effective Depth	1.45	meters
I	Bed Depth	1.75	meters

Recharger 360HD Incremental Storage Volumes

Height of System		Chamber Volume		HVLV Feed Connector Volume		Stone Volume		Cumulative Storage Volume		Total Cumulative Storage Volume		Elevation	
in	mm	ft ³	m ³	ft ³	m ³	ft ³	m ³	ft ³	m ³	ft ³	m ³	ft	m
57.0	1448	0.0	0.0	0.0	0.0	62.0	1.8	62.015	1.8	5067.84	143.50	4.750	142.29
56.0	1422	0.0	0.0	0.0	0.0	62.0	1.8	62.015	1.8	5005.82	141.75	4.670	142.26
55.0	1397	0.0	0.0	0.0	0.0	62.0	1.8	62.015	1.8	4943.81	139.99	4.580	142.24
54.0	1372	0.0	0.0	0.0	0.0	62.0	1.8	62.015	1.8	4881.79	138.24	4.500	142.21
53.0	1346	0.0	0.0	0.0	0.0	62.0	1.8	62.015	1.8	4819.78	136.48	4.420	142.19
52.0	1321	0.0	0.0	0.0	0.0	62.0	1.8	62.015	1.8	4757.76	134.72	4.330	142.16
51.0	1295	0.0	0.0	0.0	0.0	62.0	1.8	62.015	1.8	4695.75	132.97	4.250	142.14
50.0	1270	0.0	0.0	0.0	0.0	62.0	1.8	62.015	1.8	4633.73	131.21	4.170	142.11
49.0	1245	0.0	0.0	0.0	0.0	62.0	1.8	62.015	1.8	4571.71	129.46	4.080	142.08
48.0	1219	0.0	0.0	0.0	0.0	62.0	1.8	62.015	1.8	4509.70	127.70	4.000	142.06
47.0	1194	0.0	0.0	0.0	0.0	62.0	1.8	62.015	1.8	4447.68	125.94	3.920	142.03
46.0	1168	0.0	0.0	0.0	0.0	62.0	1.8	62.015	1.8	4385.67	124.19	3.830	142.01
45.0	1143	5.5	0.2	0.0	0.0	59.8	1.7	65.290	1.8	4323.65	122.43	3.750	141.98
44.0	1118	11.5	0.3	0.0	0.0	57.4	1.6	68.937	2.0	4258.36	120.58	3.670	141.96
43.0	1092	17.2	0.5	0.0	0.0	55.2	1.6	72.312	2.0	4189.43	118.63	3.580	141.93
42.0	1067	28.7	0.8	0.0	0.0	50.5	1.4	79.249	2.2	4117.12	116.58	3.500	141.91
41.0	1041	36.3	1.0	0.0	0.0	47.5	1.3	83.769	2.4	4037.87	114.34	3.420	141.88
40.0	1016	42.0	1.2	0.0	0.0	45.2	1.3	87.205	2.5	3954.10	111.97	3.330	141.86
39.0	991	46.8	1.3	0.0	0.0	43.3	1.2	90.091	2.6	3866.89	109.50	3.250	141.83
38.0	965	51.0	1.4	0.0	0.0	41.6	1.2	92.612	2.6	3776.80	106.95	3.170	141.81
37.0	940	54.7	1.6	0.0	0.0	40.1	1.1	94.864	2.7	3684.19	104.32	3.080	141.78
36.0	914	58.1	1.6	0.0	0.0	38.8	1.1	96.905	2.7	3589.33	101.64	3.000	141.75
35.0	889	61.3	1.7	0.0	0.0	37.5	1.1	98.776	2.8	3492.42	98.89	2.920	141.73
34.0	864	64.1	1.8	0.0	0.0	36.4	1.0	100.498	2.8	3393.65	96.10	2.830	141.70
33.0	838	67.1	1.9	0.0	0.0	35.2	1.0	102.289	2.9	3293.15	93.25	2.750	141.68
32.0	813	69.6	2.0	0.0	0.0	34.2	1.0	103.780	2.9	3190.86	90.35	2.670	141.65
31.0	787	71.9	2.0	0.0	0.0	33.2	0.9	105.171	3.0	3087.08	87.42	2.580	141.63
30.0	762	74.1	2.1	0.0	0.0	32.4	0.9	106.482	3.0	2981.91	84.44	2.500	141.60
29.0	737	76.2	2.2	0.0	0.0	31.5	0.9	107.719	3.1	2875.43	81.42	2.420	141.58
28.0	711	78.1	2.2	0.0	0.0	30.8	0.9	108.891	3.1	2767.71	78.37	2.330	141.55
27.0	686	80.0	2.3	0.0	0.0	30.0	0.9	110.002	3.1	2658.82	75.29	2.250	141.53
26.0	660	81.4	2.3	0.0	0.0	29.4	0.8	110.870	3.1	2548.81	72.17	2.170	141.50
25.0	635	83.1	2.4	0.0	0.0	28.8	0.8	111.877	3.2	2437.94	69.03	2.080	141.48
24.0	610	84.7	2.4	0.0	0.0	28.1	0.8	112.842	3.2	2326.07	65.87	2.000	141.45
23.0	584	86.2	2.4	0.0	0.0	27.5	0.8	113.760	3.2	2213.22	62.67	1.920	141.42
22.0	559	87.7	2.5	0.0	0.0	26.9	0.8	114.636	3.2	2099.46	59.45	1.830	141.40
21.0	533	88.8	2.5	0.0	0.0	26.5	0.8	115.282	3.3	1984.83	56.20	1.750	141.37
20.0	508	90.1	2.6	0.0	0.0	26.0	0.7	116.085	3.3	1869.55	52.94	1.670	141.35
19.0	483	91.4	2.6	0.0	0.0	25.5	0.7	116.854	3.3	1753.46	49.65	1.580	141.32
18.0	457	92.3	2.6	0.0	0.0	25.1	0.7	117.399	3.3	1636.61	46.34	1.500	141.30
17.0	432	93.5	2.6	0.0	0.0	24.6	0.7	118.103	3.3	1519.21	43.02	1.420	141.27
16.0	406	94.6	2.7	0.0	0.0	24.2	0.7	118.779	3.4	1401.11	39.67	1.330	141.25
15.0	381	95.7	2.7	0.0	0.0	23.7	0.7	119.424	3.4	1282.33	36.31	1.250	141.22
14.0	356	96.4	2.7	0.0	0.0	23.5	0.7	119.855	3.4	1162.90	32.93	1.170	141.20
13.0	330	97.4	2.8	0.0	0.0	23.1	0.7	120.447	3.4	1043.05	29.54	1.080	141.17
12.0	305	98.0	2.8	0.0	0.0	22.8	0.6	120.823	3.4	922.60	26.13	1.000	141.14
11.0	279	98.9	2.8	0.0	0.0	22.4	0.6	121.373	3.4	801.78	22.70	0.920	141.12
10.0	254	100.4	2.8	0.0	0.0	21.8	0.6	122.268	3.5	680.41	19.27	0.830	141.09
9.0	229	0.0	0.0	0.0	0.0	62.0	1.8	62.015	1.8	558.14	15.80	0.750	141.07
8.0	203	0.0	0.0	0.0	0.0	62.0	1.8	62.015	1.8	496.12	14.05	0.670	141.04
7.0	178	0.0	0.0	0.0	0.0	62.0	1.8	62.015	1.8	434.11	12.29	0.580	141.02
6.0	152	0.0	0.0	0.0	0.0	62.0	1.8	62.015	1.8	372.09	10.54	0.500	140.99
5.0	127	0.0	0.0	0.0	0.0	62.0	1.8	62.015	1.8	310.08	8.78	0.420	140.97
4.0	102	0.0	0.0	0.0	0.0	62.0	1.8	62.015	1.8	248.06	7.02	0.330	140.94
3.0	76	0.0	0.0	0.0	0.0	62.0	1.8	62.015	1.8	186.05	5.27	0.250	140.92
2.0	51	0.0	0.0	0.0	0.0	62.0	1.8	62.015	1.8	124.03	3.51	0.170	140.89
1.0	25	0.0	0.0	0.0	0.0	62.0	1.8	62.015	1.8	62.02	1.76	0.080	140.87
0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.000	0.0	0.00	0.00	0.000	140.84

Top of Stone Elevation

Top of Chamber Elevation

Bottom of Chamber Elevation

Bottom of Stone Elevation



Hydroworks Sizing Summary

Proposed Senior Living Residential Development 79 Henderson St, Port Hope

02-04-2022

Recommended Size: HydroDome HD 6

A HydroDome HD 6 is recommended to provide 80 % annual TSS removal based on a drainage area of 1.821 (ha) with an imperviousness of 65 % and Peterborough, Ontario rainfall for the 20 um to 2000 um particle size distribution.

The recommended HydroDome HD 6 treats 86 % of the annual runoff and provides 81 % annual TSS removal for the Peterborough rainfall records and 20 um to 2000 um particle size distribution.

The HydroDome has a siphon which creates a discontinuity in headloss. The given peak flow of .03 (m³/s) is less than the full pipe flow of 21.68 (m³/s) indicating free flow in the pipe during the peak flow assuming no tailwater condition. Partial pipe flow was assumed for the headloss calculations. The headloss was calculated to be 208 (mm) above the crown of the 600 (mm) outlet pipe.

This summary report provides the main parameters that were used for sizing. These parameters are shown on the summary tables and graphs provided in this report.

If you have any questions regarding this sizing summary please do not hesitate to contact Hydroworks at 888-290-7900 or email us at support@hydroworks.com.

The sizing program is for sizing purposes only and does not address any site specific parameters such as hydraulic gradeline, tailwater submergence, groundwater, soils bearing capacity, etc. Headloss calculations are not a hydraulic gradeline calculation since this requires a starting water level and an analysis of the entire system downstream of the HydroDome .

TSS Removal Sizing Summary

Hydroworks Siphon Separator Sizing Program - HydroDome

File Product Units CAD Video Help

General | Dimensions | Rainfall | Site | TSS PSD | TSS Loading | Quantity Storage | By-Pass | Custom | CAD | Video | Other

Site Parameters: Area (ha) 1.821, Imperviousness (%) 65

Units: U.S., Metric

Rainfall Station: Peterborough, Ontario, 1971 to 2006, Rainfall Timestep = 60 min.

Project Title (2 lines): Proposed Senior Living Residential Development, 79 Henderson St, Port Hope

ETV Lab Testing Results: Post Treatment Recharge

Outlet Pipe: Diam. (mm) 600, Slope (%) 1, Peak Design Flow (m3/s) .030

HydroDome Annual Sizing Results				
Model #	Qlow (m3/s)	Qtot (m3/s)	Flow Capture (%)	TSS Removal (%)
Unavailable	.03	.03	86 %	64 %
HD 4	.03	.03	86 %	71 %
HD 5	.03	.03	86 %	77 %
HD 6	.03	.03	86 %	81 %
Unavailable	.03	.03	86 %	82 %
HD 8	.03	.03	86 %	84 %
HD 10	.03	.03	86 %	88 %
HD 12	.03	.03	86 %	88 %

Particle Size Distribution		
Size (um)	%	SG
20	20	2.65
60	20	2.65
150	20	2.65
400	20	2.65
2000	20	2.65

Note: Results vary significantly based on particle size distribution

Simulate

TSS Particle Size Distribution

Hydroworks Siphon Separator Sizing Program - HydroDome

File Product Units CAD Video Help

General | Dimensions | Rainfall | Site | TSS PSD | TSS Loading | Quantity Storage | By-Pass | Custom | CAD | Video | Other

TSS Particle Size Distribution			
	Size (um)	%	SG
▶	20	20	2.65
	60	20	2.65
	150	20	2.65
	400	20	2.65
	2000	20	2.65
*			

Notes:

- To change data just click a cell and type in the new value(s)
- To add a row just go to the bottom of the table and start typing.
- To delete a row, select the row by clicking on the first pointer column, then press delete
- To sort the table click on one of the column headings

TSS Distributions:

Standard Design

ETV Canada

OK110

Toronto

Ontario Fine

Calgary Forebay


Kitchener

User Defined

Clear

You must select a particle size distribution for TSS to simulate TSS removal

Water Temp (C) 20



Site Physical Characteristics

Hydroworks Siphon Separator Sizing Program - HydroDome

File Product Units CAD Video Help

General | Dimensions | Rainfall | Site | TSS PSD | TSS Loading | Quantity Storage | By-Pass | Custom | CAD | Video | Other

Catchment Parameters

Width (m) Imperv. Mannings n Maintenance Frequency (months)

Perv Mannings n

Slope (%) Imp. Depress. Storage (mm)

Perv. Depress. Storage (mm)

Daily Evaporation (mm/day)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
0	0	0	2.54	2.54	3.81	3.81	3.81	2.54	2.54	0	0

Infiltration

Max. Infiltration Rate (mm/hr)

Min. Infiltration Rate (mm/hr)

Infiltration Decay Rate (1/s)

Infiltration Regen. Rate (1/s)

Catch Basins

of Catch basins

Controlled Roof Runoff

Roof Runoff (m3/s)

Dimensions And Capacities

Hydroworks Siphon Separator Sizing Program - HydroDome


File Product Units CAD Video Help

General Dimensions Rainfall Site TSS PSD TSS Loading Quantity Storage By-Pass Custom CAD Video Other

Dimensions and Capacities					
Model	Diam. (m)	Depth (m)	Float. Vol. (L)	Sediment Vol. (m3)	Total Vol. (m3)
HD 3	0.91	1.22	114	0.3	0.8
HD 4	1.22	1.37	243	0.6	1.6
HD 5	1.52	1.68	442	1.1	3.1
HD 6	1.83	1.98	728	1.9	5.2
HD 7	2.13	2.29	1114	3	8.2
HD 8	2.44	2.59	1698	4.3	12.1
HD 10	3.05	3.2	3284	8.2	23.3
HD 12	3.66	3.81	5639	13.9	40

Depth = Depth from outlet invert to inside bottom of tank

Generic HD 6 CAD Drawing



TSS Buildup And Washoff

Hydroworks Siphon Separator Sizing Program - HydroDome

File Product Units CAD Video Help

General | Dimensions | Rainfall | Site | TSS PSD | TSS Loading | Quantity Storage | By-Pass | Custom | CAD | Video | Other

TSS Buildup

Power Linear
 Exponential
 Michaelis-Menton

TSS Washoff

Power-Exponential
 Rating Curve (no upper limit)
 Rating Curve (limited to buildup)

Street Sweeping

Efficiency (%)
 Start Month
 Stop Month
 Frequency (days)
 Available Fraction

Soil Erosion
 Add Erosion to TSS

TSS Buildup Parameters

Limit (kg/ha)
 Coeff (kg/ha)
 Exponent

TSS Washoff Parameters

Coefficient
 Exponent

TSS Buildup

Based on Area
 Based on Curb Length

Upstream Quantity Storage

Hydroworks Siphon Separator Sizing Program - HydroDome

File Product Units CAD Video Help

General | Dimensions | Rainfall | Site | TSS PSD | TSS Loading | Quantity Storage | By-Pass | Custom | CAD | Video | Other

Quantity Control Storage

	Storage (m3)	Discharge (m3/s)
	0	0
	40	20
▶	143.5	30
*		

Notes:

1. To change data just click a cell and type in the new value (s)
2. To add a row just go to the bottom of the table and start typing.
3. To delete a row, select the row by clicking on the first pointer column, then press delete
4. To sort the table click on one of the column headings

Other Parameters

The screenshot shows the 'Hydroworks Siphon Separator Sizing Program - HydroDome' window. The 'Other' tab is selected in the top navigation bar. The interface contains several sections with checkboxes and a text input field:

- Scaling Law:**
 - Peclet Scaling based on diameter x depth
 - Peclet Scaling based on surface area (diameter x diameter)
- HydroDome Design:**
 - High Flow Weir
 - Flow Control (parking lot storage)
Must add Quantity Storage Table
- TSS Removal Extrapolation:**
 - Extrapolate TSS Removal for flows lower than tested
 - No TSS Removal extrapolation for flows lower than tested
 - No TSS Removal extrapolation for lower flows or inter-event periods
- Lab Testing:**
 - Use NJDEP Lab Testing Results
 - Use ETV Canada Lab Testing Results
- TSS Removal Results:**
 - Required TSS Removal
 - Choose Model #
- TSS Removal Required:**
 - TSS Removal (%) Enter required TSS Removal (%)

Hydroworks Sizing Program - Version 5.5
Copyright Hydroworks, LLC, 2021

APPENDIX E

ODAN/DETECH GROUP ENGINEERING DRAWINGS
CONCEPT SITE SERVICING
CONCEPT SITE GRADING